



STATE OF DELAWARE
DEPARTMENT OF TRANSPORTATION
PO BOX 778
DOVER, DELAWARE 19903

JACK MARKELL
GOVERNOR

SHAILEN BHATT
SECRETARY

VIA OVERNIGHT DELIVERY

(302) 760-2030
FAX (302) 739-2254

September 20, 2012

Contract No. T201280101.02
FABRIC BUILDING REPLACEMENT
Statewide County

Ladies and Gentlemen:

Enclosed is Addendum No. 1 for the referenced contract consisting of the following:

1. Twenty-eight (28) page, Pre Bid Meeting Transcript, new, to be added to the Proposal.

Questions and Answers

As discussed, for the Fabric buildings, we will accept the additional material:

PVC (Polyvinyl Chloride)

- a. Raw Material: Polyester
- b. Construction: PVC/PVDF Coated Polyester
- c. Tensile Strength: to meet design requirements
- d. Light Transmission: 8%-14%, with respect to associated required strength
- e. Color: White
- f. Flame Retardancy: NFPA 701
- g. Composure: Solid and water repellent
- h. Seams: RF Sealed with sufficient strength to develop 90 percent of full strength of fabric
- i. Minimum of 28 ounces per cubic yard total weight

Additionally, we find the option of zinc coating instead of galvanization "acceptable" with the specs given.

Zinc Coating conforming to the following specs:

Corrosion Protection: All steel tube components, trusses, purling, fastening tubes shall be coated, on the exterior, with a gloss finishing providing a corrosion resistance of 1800 hours as per ASTM B117-90;

Coatings: Zinc conforms to ASTM B6, Standard Specifications for Zinc, High Grade (1.1.3.) and Special High Grade (1.1.2.).

- a. Exterior: In-line galvanized to a normal coating zinc weight of 0.6 oz/ft². Chromate conversion coating applied over the galvanized surface to provide additional corrosion protection. Clear organic polymer applied as the top surface coat to retard oxidation, enhance surface appearance and provide a primer for subsequent painting or powder coating processes as desired.

Please note the revisions listed above and submit your bid based upon this information.

Sincerely,

A handwritten signature in black ink, appearing to read "Scott S. Gottfried". The signature is fluid and cursive, with a long horizontal stroke at the beginning.

Scott S. Gottfried
Competitively Bid Contracts Coordinator
:ssg
Enclosures