

Delaware Department of Transportation

CLARIFICATION

T200412201.01

SR 1, THOMPSONVILLE GRADE SEPARATED INTERSECTION/KENT COUNTY

Monday, October 27, 2014

2	Where are the details for Item 614508 found on the Plans? On the breakout sheet for this item you show 2 each water valves (w-3). Are these two valves in addition to the two each you shown in item W-6, which is a 10" x 10" tapping sleeve and valve? Does the existing 10" main get abandoned in place	Yes, the bid price for Item #614508 should include 2 W-3 and 2 W-6 as shown on the breakout sheet. The existing 10" main is abandoned in place.
1	What specific Hot Mix is used for driveways? Where is that shown on the plans?	Refer to plan note #8 on sheet 4. The type of Type C was based on the pavement section of the roadway adjacent to the driveway.