

Delaware Department of Transportation
QUESTIONS AND ANSWERS
T201330011.01

Yellow highlighting = previous question
answered in this posting: Q1

BRECKNOCK PARK MULTI-USE TRAIL, KENT COUNTY
Monday, July 24, 2017

Q #	Question	Answer
1	The advertisement calls for Temporary Impact Attenuator, Gating, Non-Redirective #809003, but the drawing indicates a need for Temporary Impact Attenuator, Non-Gating, Redirective, #809005?	After reviewing the plans, it was determined that the temporary impact attenuator (Item 809003) is incorrect. The estimate and bid package should call for Item No. 809005 - FURNISH TEMPORARY IMPACT ATTENUATOR - NON-GATING, REDIRECTIVE, TEST LEVEL 3. This will be addressed in Addendum No. 1.