

Delaware Department of Transportation
QUESTIONS AND ANSWERS
T201707702.01
BRIDGE DECK SEALING, FY18, NEW CASTLE COUNTY
Wednesday, November 22, 2017

Q #	Question	Answer
5	If quantities used are significantly lower than estimated quantities in the bid, will contractor have the ability to renegotiate unit price?	<i>Response forthcoming...</i>
4	Who is responsible for removal of homeless camps for purposes of sealing of abutment backwalls?	Only top surfaces of the abutment backwalls shall be sealed, which are accessible from the top of bridge decks.
3	In regards to silicone joint seal, is removal of old joint seal required prior to new installations?	As per Section 624 of the Standard Specifications for Road and Bridge Construction, 2016: Price and payment for silicone seal constitutes full compensation for removing and disposing existing seal, furnishing and placing all Materials, cleaning and preparing the joint, and for all labor, Equipment, tools, and incidentals necessary to

Wednesday, November 15, 2017

2	What is required for prep work prior to sealing of the bridges?	Refer to “Delaware Standard Specifications, August, 2016”, SECTION 613 – CONCRETE COATINGS AND MEMBRANES for Construction requirements.
1	Please advise why there is no DBE on this project?	We reviewed the goal for this project. The limited diversity of the work items listed in the estimate and the Delaware certified DBE firms that we have that perform those work items were extremely low. Our focus will be on race-neutral participation in this project.