

Delaware Department of Transportation

**QUESTIONS AND ANSWERS**

**T201606118.01**

**Pavement and Rehabilitation, North XVIII, 2016, New Castle County**

**Wednesday, November 21, 2018**

Poster

Q #	Question	Answer
3	What bituminous pavement item is to be used for the guardrail maintenance pavement?	Item 401044 Superpave Type C, PG 64-22 (Non-Carbonate) will be used for the guardrail maintenance pavement for this contract.
2	ADA Design plan project note #10 states “THE CONTRACTOR SHALL DELIVER ALL EXCESS MILLED MATERIAL TO THE DEPARTMENT OF TRANSPORTATION’S MAINTENANCE YARD.” What maintenance yard will be taking the millings, and does the Department want all of the milled material generated from this contract?	Millings will be the property of the Contractor. Disregard Note #10, it does not apply to this contract.
1	Special provision for Item 503503 Patching Concrete indicates this is a fixed price item, but the disk or proposal forms do not indicate the fixed price. Is this item to be bid at the specified fixed price or can we submit a price for this item?	Item 503503 is a fixed price item at \$5.65 and should be bid as such.