

Delaware Department of Transportation

QUESTIONS AND ANSWERS

T201606902.01

CONVERSION ROADS, SOUTH, 2016, SUSSEX COUNTY

Monday, December 28, 2015

Q #	Question	Answer
3	It appears that some of the pipe runs will require removal of the existing sack concrete wall. What is required at these locations?	The intent is to leave the existing sack concrete walls in place during the replacement. If that is not possible, and the wall becomes compromised during construction, the wall is to be removed and replaced with a R-4 or R-5 riprap slope.
2	Will new pipe be placed at the same invert elevation As the existing pipe?	Yes.
1	Will all new pipe runs require removal of existing pipe?	Yes.