

Delaware Department of Transportation

**QUESTIONS AND ANSWERS**

**DOT1706-FENCE\_NB**

**Right of Way Fence Replacement, North District, Open End, FY 18-19**

**Monday, May 15, 2017**

Q #	Question	Answer
9	On breakout sheet 2, item 7, what do you mean by “patches”?	A “Patch” refers to replacing the fabric in a right of way fence vehicular/ walk gate.
8	On breakout sheet 1, item 5, is there a standard drawing for what you mean by a flap gate?	There is no Standard Construction Detail for a flap gate. A flap gate, is a gate that rotates vertically rather than horizontally.
7	Item 0150 - Emergency mobilization, what is the criteria for when we would get paid for this?	Please refer to the special provision provided in the Contract for Item 763507 – Emergency Mobilization.
6	Item 0140 - initial expense, de-mobilization - is there a description of what I can charge for in this line item? ie. can I include costs associated with getting equipped for traffic controls, etc. here?	Please refer to Section 763 ( Initial Expense/ De-Mobilization) of the 2016 Standard Specifications for a description of this item.
5	Item 0080 - right of way fence gate - what size, width? Swing or Slide?	This will be addressed in Addendum #1.
4	Item 0070 - chain link fence gate - what size? Height and Width? Swing or slide?	This will be addressed in Addendum #1.
3	Item 0060 - Decorative Fence - is there s standard drawing for what you are looking for? Height? Color?	There is no Standard Construction Detail for Item 727005. There is no defined color. The height designations will be addressed in Addendum #1.
2	Item 0050 - Wood Vertical Slat Fence - is there a standard drawing for what you are looking for? Height?	There is no Standard Construction Detail for Item 727004. The height designations will be addressed in Addendum #1.
1	Item 0040 - Vinyl Post and rail fence - is there a standard drawing for what you are looking for? Color?	Standard Construction Detail M-5 (Wood Rail Fence) would be the applicable standard drawing for Item 727003. Please refer to the 2016 Standard Specifications Section 1061.05 (Post and Rail Fence) for the material specifications. There is no defined color.