

Delaware Department of Transportation
QUESTIONS AND ANSWERS
T200411209.01
SR 24, MULBERRY KNOLL TO SR 1, SUSSEX COUNTY
Wednesday, October 23, 2019

Q #	Question	Answer
3	TRM is noted to be paid under 402000 in the Sequence Notes of the Phase Plans. Is this a typo? TRM is Item 403000.	The sequence notes on the phasing plans will be updated to reference item 403000. This change will be included in the forthcoming addendum.

Monday, October 21, 2019

2	Please refer to the light pole and luminaire items and quantities. I can only account for the (7) each 30' Single Davit Arm Poles (Item 851001) on the lighting plans (Sheets 67 and 68). According to Note 2 on Sheet 68 the Luminaires are incidental to these poles. I am assuming the Power Company (DEC) is responsible for the (5) arms and Luminaires (#'s 8-12 on sheet 67) that go on their wood poles. What is the intention of Items 850521, 851003, and 851004?	Items 850521, 851003 & 851004 will be removed from the contract as per forthcoming addendum.
1	The bid items list shows (14) Aluminum Lighting Poles (851001, 851003, 851004) but plans (P67) only show (7) poles. Please provide drawings for the remaining poles that shows the arm lengths.	Items 851003 and 851004 will be deleted from the contract as per forthcoming addendum. Updated lighting plans and quantity for Item 851001 will also be included in the addendum.