

Delaware Department of Transportation

QUESTIONS AND ANSWERS

T201200107.01

HEP NCC, SR896 AND PORTER ROAD INTERSECTION IMPROVEMENTS

Thursday, January 30, 2014

Q #	Question	Answer
8	On pages 30 and 31 there are listings of signs and posts to be removed or replaced but there are no bid items for this work. Who does this work and how is it paid?	If signs and posts are to be removed or replaced, it will be addressed in the field.

Wednesday, January 29, 2014

7	On plan sheet #19, General Note #8 is calling for item #743501 and item #734514 but neither item is on the contract schedule of items. Shall everything involving the message boards be incidental to item #743004?	Everything involving the message board should be included under item #743004. The note will be revised as part of addendum #2.
---	---	--

Tuesday, January 28, 2014

6	Plan Sheet 7 shows a total widening of 17' while typical section on Plan Sheet 5 shows a 22' widening. Please clarify which is correct.	The total widening is 17'. The dimension of plan sheet 5 will be revised as part of addendum #2.
5	Ref Note 5 under Section 200 on Plan Sheet 4 indicates that the following items are to be removed under Item 211000, drainage inlets and decorative poles. I don't see these items designated to remove by contractor on the construction plans. Please clarify.	There are no drainage inlets or decorative poles to be removed as part of the project. the note will be revised as part of addendum #2.
4	Please clarify note 10 on Plan Sheet 19.	The note refers to signs to be installed by the contractor and are included on the signing and striping plans. The note will be clarified as part of addendum #2.
3	What are the limits on clearing on this project the LOC or CZ?	The limit of clearing is the LOC.
2	Reference the Earthwork Summary on Plan Sheet 4. This earthwork summary does not contain any quantities, please clarify.	Quantities will be added to the earthwork summary and distributed in addendum #2.
1	Are cross-sections available for this contract?	No cross sections are available for this contract