

Delaware Department of Transportation

QUESTIONS AND ANSWERS

T201206105.01

PAVEMENT & REHABILITATION, NORTH V, 2012/ NEW CASTLE COUNTY

Thursday, August 21, 2014

Q #	Question	Answer
3	Other than 100 LF of PCC Curb TY 2 and 300 SF of sidewalk what are removing under Item 758000 to equal 155 SY?	Additional quantity for 758000 is always included for removal and replacement of PCC curb or sidewalk that may be associated with ADA upgrades.
2	What is Item 302007 used for at Location #1?	GABC quantity included for the turn lane extension. See page 33C.
1	What is Item 202000 used for at Location #1? What is the depth of excavation?	Excavation quantity included for turn lane extension. Depth will be determined in the field.