

Delaware Department of Transportation

QUESTIONS AND ANSWERS

T201207101.02

BR 1-159 ON JAMES STREET OVER CHRISTINA RIVER, NEW CASTLE COUNTY

Wednesday, August 07, 2019

Q #	Question	Answer
3	<p>The Special provision for item 763620 requires the Geotechnical Instrumentation Engineer to be a Professional Engineer registered in the state of Delaware, this requirement excludes engineers that have vast nationwide experience in project design, installation and monitoring including development of devices, software interface and defining geotechnical limits for reporting.</p> <p>Please consider allowing experience Registered Professional Engineers from other States to be the Geotechnical Instrumentation Engineer upon review of qualifications.</p>	<p>24 DE. C. §2802 requires someone practicing engineering in Delaware to be licensed in the State of Delaware. It is reasonable to assume a national expert would be a registered professional engineer in some state, so we expect him/her to apply for licensure in Delaware to participate in this project. The reciprocity process is simple, and the licensure fees are minor. More information can be found at: https://www.dape.org/</p> <p>Regarding the qualifications, we will consider said expert for this project, provided s/he is a professional engineer in some state and is in the process of becoming licensed in Delaware.</p>
2	<p>Is there going to be a specification for the CPM schedule and updates added to the RFP?</p>	<p>Yes, Special Provisions for CPM schedule and CPM updates were unintentionally omitted and were added via Addendum No. 1.</p>

Friday, July 12, 2019

1	<p>What type luminaires are required Type A or Type B?</p>	<p>The luminaires required are Type A in accordance with Item Specification 746669. The reason for this is because Type A calls for a NEMA type 3 distribution.</p>
---	--	---