

Delaware Department of Transportation

QUESTIONS AND ANSWERS

T201207103.01

BR 1-543 ON N213 CARR ROAD OVER SHELLPOT CREEK, NEW CASTLE COUNTY

Friday, September 16, 2016

Q #	Question	Answer
3	We do not believe that 103 Calendar Days is sufficient time to complete this project. The stone masonry work on this project cannot be done until the parapet concrete has been placed. This stone masonry work, by itself, could take up to 30 days to complete. Please consider adding 30 days to the contract time.	The completion time will not be changed.
Wednesday, September 14, 2016		
2	Sheet 16 of 26 shows the structural steel and framing plan. There are no details of bearings. Can you please provide them?	There is no bearings on this project. The beam is sitting directly on the concrete.
Wednesday, September 07, 2016		
1	What is Item 302512 – Furnish Stone to be used for?	Item 302512 – Furnish Stone, is to provide additional stone if the existing stone to be reused is inadequate to complete the job.