

Delaware Department of Transportation

QUESTIONS AND ANSWERS

T201207604.01

SUSSEX COUNTY PIPE REPLACEMENTS, FEDERAL, 2012

Friday, April 24, 2015

Q #	Question	Answer
1	There is a bid item 601520, Temporary Timber Mat for bridge 3-941. The plans do not show where this timber matting is to be placed. Where does the Department intend for the Contractor to place this temporary timber mat? The bid item is lump sum so we need to know the surface area you want matted.	Timber mats are intended for use at Bridge 3-941 only and are to be used for all equipment traversing delineated wetland areas. Refer to Note 5A on Sheet 35 for further guidance on the placement of timber mats.