

Delaware Department of Transportation

**QUESTIONS AND ANSWERS**

**T201220012.01**

**LEWES HISTORICAL SOCIETY PEDESTRIAN IMPROVEMENTS, SUSSEX COUNTY**

**Wednesday, July 09, 2014**

Q #	Question	Answer
2	On page 70 of the Special Provisions it states to use 2ea 18" long # 13 rebar to pin the concrete parking bumpers. Is # 13 rebar a new size or a typo ? The plans say use # 8 rebar, please clarify.	In review, there is a typo in the specification. The parking bumpers shall be anchored with two (2) 18 inch number 8 rebars. The spec incorrectly calls out number 13 rebars.
1	Page 32 of the Bid Proposal, is it the "rate" or "fringes" ?  Items pervious concrete, unit paver and edger stone all seem to be 15-20 % high in quantity or units. Please adjust the quantity/unit to reflect the work on the plans.	The column headings are misaligned. All figures shown are "Rates", there are no "Fringes".  We reviewed the quantities for Pervious Concrete (501532), Edger Stone (701504), and Unit Paver (705510) and have confirmed that they are acceptable and reflect the proposed work in the project.