

Delaware Department of Transportation
QUESTIONS AND ANSWERS
T201300303.01
HEP SC US13 @ S46/SUSSEX COUNTY
Monday, March 09, 2015

Q #	Question	Answer

Wednesday, March 04, 2015

2	Will top of grate and invert elevations be provided for the drainage inlets prior to the bid?	Invert elevation for drainage inlet #2 is provided in the drainage inlet schedule. Invert elevations for drainage inlets # 1 and #3 are to match the existing pipe invert, as noted in the drainage inlet schedule. Top of grate for drainage inlets # 1 and #2 are to match the proposed curb flow line, as noted in the drainage inlet schedule. Top of grate for drainage inlet #3 is to be set at elevation 30.41.
---	---	--

Monday, March 02, 2015

1	Is there a detail on the method of connecting P1 to the existing pipe?	No.
---	--	-----