

Delaware Department of Transportation

QUESTIONS AND ANSWERS

T201401101.01

SR72, Advanced Utility Relocation from McCoy Road to SR71 New Castle County

Friday, October 26, 2018

Q #	Question	Answer
2	The plans lay out a pedestrian detour. There is a line item to pay for the signs on the detour - 810001, but there is not a line item to pay for the Type III Barricades on the detour plan (813001).	Line item for barricades was added in Addendum 2.
1	Sheet 18 of 87, CP-01, lists FES 120 and FES 121 as 6:1 Safety ES per standard detail D-1. This detail is for round pipe only and , will not accommodate a 14x23 ERCP (P-120). Please verify if standard Flared End Sections will be used on this pipe run.	The pipe associated with these flared end sections is changed to round 18" pipes. This change is reflected in addendum 1.