

Delaware Department of Transportation

QUESTIONS AND ANSWERS

T201403101.01

COMMUNITY TRANSPORTATION FUND, NORTH I, 2014 OPEN END NEW CASTLE COUNTY

Friday, February 21, 2014

Q #	Question	Answer
-----	----------	--------

Tuesday, February 18, 2014

3	Can DelDOT provide an accurate linear footage of hot mix saw cut to be incorporated into bid items 760000 & 760006 or will DelDOT consider paying for the saw cut at the joint under bid item 762001?	The saw cut at the joint will not be paid for under 762001. Please refer to question no. 2 response.
---	---	--

Friday, February 14, 2014

2	If the existing road surface is to be milled under bid items 760000 and/or 760006, will the contractor be paid for all the required hot mix sawcuts, bid item 762001, where the existing bituminous pavement meets the proposed pavement; including the beginning and end of the project limits, all intersecting street, and all driveways?	The Saw Cut item will not be paid for where the existing bituminous pavement meets the proposed pavement or at intersecting streets. Per General note number 8 . BUTT JOINTS IN FULL MILL AREAS SHALL BE INCIDENTAL TO THE PAVEMENT MILLING ITEM. SAWCUTS FOR BUTT JOINTS SHALL BE INCIDENTAL TO THE BUTT JOINT ITEM.
1	What is the possibility that we can have the (3) Contracts bid in three consecutive weeks?	The Department is considering moving one project's bid date. If a bid date is be moved on a project, an addendum will be posted.