

Delaware Department of Transportation

QUESTIONS AND ANSWERS

T201406101.01

PAVEMENT AND REHABILITATION, NORTH I, 2014 NEW CASTLE COUNTY

Friday, January 17, 2014

Q #	Question	Answer
4	Is Item 302005 used only under concrete curbs and walks?	No. At the discretion of the engineer, this item may be used in conjunction with Item # 406001, Bituminous Patching, and Item # 401823, BCC 64-22 Warm mix (Patching).
3	What is the location of the taper mill at location 2?	As written on pages 20 and 21 of 30 in Plans and Specifications, under General Improvements Header. "Remaining areas not previously identified - taper mill @ curb and guardrails, with 1.5 " Type C 64-22 WMA overlay"
2	The quantity for Item 758000 does not appear to be correct. Please verify.	Field Estimate Quantities and Calculations were reviewed and found to be accurate.
1	At Location 3 what is Item 202000 used for?	Excavation and Embankment item may be, or is anticipated to be utilized for work outside pay limits for Item #710001 Adjust and Repair existing Drainage Inlet.