

Delaware Department of Transportation

QUESTIONS AND ANSWERS

T201506202.01

PAVEMENT & REHABILITATION, KENT II, (MILFORD AREA) 2015, KENT COUNTY

Thursday, August 27, 2015

Q #	Question	Answer
1	None of the locations listed in the plans have the typical note stating it has to meet the tolerances of subsection 401580 – Ride Quality of Hot Mix Pavement. However, 401580 is in the Special Provisions. Will any of the locations be held to the requirements of 401580?	Location 3 will be held to the requirements for 401580. Note has been added to plan sheet no. 24. Please see Addendum No. 1.