

Delaware Department of Transportation

**QUESTIONS AND ANSWERS**

**T201507601.01**

**BR 3-253 N&S ON US 13 OVER WILLIAMS POND, SUSSEX COUNTY**

**Wednesday, April 20, 2016**

<b>Q #</b>	<b>Question</b>	<b>Answer</b>
3	Is the existing coating Hazardous?	Yes – coal tar epoxy
2	Which paint system is to be used?	Urethane Paint System as specified in Item 605522
1	Pier repairs show cleaning and painting of exposed steel piles. Which item will this be paid under?	605522 and 605533 (see note 8 on sheet 8)