

Delaware Department of Transportation
QUESTIONS AND ANSWERS
T201603201.01
CTF PROJECTS CENTRAL, FY 2016, 2017, & 2018, KENT COUNTY
Tuesday, May 10, 2016

Q #	Question	Answer
1	What size pipe does item 708563 PERSONNEL GRATE FOR PIPE INLET go on?	15", 18", 30" & 24"x38"