

Delaware Department of Transportation

QUESTIONS AND ANSWERS

T201607303.01

PRIME HOOK ROAD IMPROVEMENTS, SUSSEX COUNTY

Friday, October 23, 2015

Q #	Question	Answer
2	The bid form includes item 406001, Bituminous Concrete Patching. However, there are not any items for placing hot mix in the patches. How does the Department intend to measure and pay for the hot mix placed for the patching?	The hot mix for patching will be paid for under 401810-WMA, Superpave, Type B Hotmix, 160 Gyrations, PG 64-22 as stated in the standard Specification for 4060014-Bituminous Concrete Patching.
1	There is a note on plan pages 7 & 8 about removing existing stone within the LOC. How will this stone removal measured and paid?	This shall be paid for under 202000.