

Delaware Department of Transportation

**QUESTIONS AND ANSWERS**

**T201706402.01**

**PCC PATCHING, INTERSTATE, NORTH, OPEN END, FY17-19, NEW CASTLE COUNTY**

**Friday, January 13, 2017**

<b>Q #</b>	<b>Question</b>	<b>Answer</b>
1	Item #809003, Furnish Temporary Impact Attenuator, Gating, Non-Redirective, Test Level 3. Usually a Non-Gating, Redirective Attenuator is used on the Interstate. Is this a change in the State specifications?	The item should have been Item 809005 - Furnish Temporary Impact Attenuator, Non-Gating, Redirective, Test Level 3. This item change will be addressed in Addendum #1.