

Delaware Department of Transportation  
**QUESTIONS AND ANSWERS**  
**T201807702.01**

Yellow highlighting = previous questions answered  
in this posting: Q3

**Structure Maintenance, North District, Open End, FY19-21, New Castle County**  
**Friday, April 06, 2018**

Q #	Question	Answer
-----	----------	--------

**Thursday, April 05, 2018**

3	Regarding Item 611004; Zinc & Epoxy Dual Coated Bars, I am being told that this material is not available any longer (Z Bar). If this is untrue, please advise potential sources of supply (not binding upon the Department). If this is true, can the item be changed to standard epoxy coated bar?	Item 611004 (Bar Reinforcement, Zinc & Epoxy Dual Coated) will be changed to Item 611001 (Bar Reinforcement, Epoxy Coted) via addendum.
---	--	---

**Tuesday, April 03, 2018**

2	For Item 625001 Furnishing Latex Modified Concrete Overlay, should there be the companion Item 625000. Installation of the Latex Concrete Overlay. Should this Item be added to the Contract?	Yes, this item will be added via addendum.
---	---	--

**Tuesday, March 27, 2018**

1	Item 817009 is for 4" temp tape and per everything except the proposal is to be paid per LF. The proposal indicates SF. Please confirm this item is paid per LF.	The unit of measure for Item 817009 on the bid form has been changed to LF in Addendum No. 1.
---	--	---