

Delaware Department of Transportation

**QUESTIONS AND ANSWERS**

**T201809001.01**

**SR141 Advance Utility Relocation under Southbound I-95, New Castle County**

**Friday, November 09, 2018**

Q #	Question	Answer
1	Are there plans available that show the placement of the barrier wall and the temporary impact attenuators?	There are no plans that show the temporary barrier wall or temporary impact attenuators.  On Sheet 18, M.O.T. Note 2, we call out for the use of TA-5A. TA-5A includes the use of temporary barrier wall and attenuator. The contractor should refer to the DE MUTCD, TA-5A for the use of the temp barrier wall and attenuator.