

Delaware Department of Transportation

QUESTIONS AND ANSWERS

T201701103.01

**SR 2, KIRKWOOD HIGHWAY, SR 7 TO DUNCAN ROAD PEDESTRIAN
ACCESS ROUTES (PAR) IMPROVEMENTS**

Tuesday, May 26, 2020

Q #	Question	Answer
2	For Item 601011 15” RCC Pipe Class III, Sheet No. 11 of the Plans shows this Pipe to be Class IV. Is this correct? Should an Item be created for Class IV 15” Pipe?	All proposed RCP should be bid as Item 601011, 15” RCP, Class III.

Friday, May 15, 2020

1	Please provide a detail and list of vendors for line 0380 – item 721515 – Guardrail Post Cap, for which the contract specifications list a product called “N-CAP or an approved equal”.	Item 721515 – Guardrail Post Cap is available through AWN Safety Products. AWN Safety Product contact information is awnsafetyproducts@gmail.com or 336-831-3085.
---	---	---