

Delaware Department of Transportation

QUESTIONS AND ANSWERS

T201901101.01

MILLER ROAD STREETSCAPE IMPROVEMENTS, NEW CASTLE COUNTY

Monday, March 09, 2020

Q #	Question	Answer
1	Note 3 on Plan Sheet 5 indicates that existing inlets and pipes within the project limits shall be cleaned out and the cost is incidental to 201000 Clearing & Grubbing. DelDOT typically uses individual pay items for cleaning, heavy cleaning, etc since this effort has considerable unknowns (601000, 601001, 601002). Can this cleaning being paid under the unit prices? If not, please provide a specification that defines the requirements for cleaning along with a description of the condition of the existing pipes so that we can price accordingly.	Please see Section 601.03.9 Cleaning Pipe of the Supplemental Specifications to the August 2016 Standard Specifications (Revised June 15, 2018) for guidance on cleaning all pipes within the project limits and within the State right-of-way. No heavy cleaning is required.