

Delaware Department of Transportation  
**QUESTIONS AND ANSWERS**  
**T202006301**  
**PAVEMENT & REHABILITATION, SUSSEX I,**  
**(US 13, SUSSEX HWY - SEAFORD) 2020 - ROAD SYSTEMS**  
**Friday, September 11, 2020**

| Q # | Question   | Answer  |
|-----|--|---|
| 3   | What conversion factor does the department use to convert cubic yards of millings to tons?   | 3272.4 lbs per cubic yard as referenced from the Del-DOT Design Resource Center, Pavement & Materials, Material Average Weight Chart.   |
| 2   | When the contractor delivers millings to the Del DOT yard, will the truck be required to be weighed at the scale?  | Yes.  |
| 1   | Just to clarify, will the Contractor be permitted nighttime work hours for a minimum of 5 days/week? The plans show nighttime work hours occurring just 4 nights/week (Sun PM – Thur AM) which does not seem feasible. | Yes, the Contractor is permitted to work a minimum of 5 days;<br>Sunday - 8pm to 6am.<br>Monday - 8pm to 6am.<br>Tuesday - 8pm to 6am.<br>Wednesday - 8pm to 6am.<br>Thursday - 8pm to 6am. |