

Delaware Department of Transportation

Questions and Answers

Project Number: T202153104.03

Project Title: DOVER BUS CANOPY SOLAR PANELS - READVERTISEMENT

Posted to Web Site: Tuesday, July 21, 2026

Q #	Question	Answer
4	Conduit and Wire schedule on sheet E-503 references panel H-2. H-2 is not shown on the floor plan. Please advise	The floor plan showing the electrical room location is attached. Also included is the panel schedule for panel H-2.
3	Please provide a floor plan of the existing building indicating existing walls, electrical room location and communication room location so pathways for the new service and comms conduits can be determined.	The floor plan identifies the Comm Room location. The building floor plan identifies columns and the column wall detail.
2	The plans indicate a new secondary feeder. Can any of the existing conduit be reused? What temporary power requirements will be required and who is required to provide them? What are the requirements for shut down to integrate the new ECC and new feeder connection?	Existing feeders may be re-used if there is enough available capacity. No temporary power is anticipated for this installation. Project has been phased to ensure lighting is maintained on the lot through the construction process. Service is only for bus charging and can be disconnected during upgrade of system.
1	The plans indicate a reference to a Geotech report to be used in developing canopy footing design. Please provide the Geotech report or provide the assumed soil bearing capacity.	The Geotechnical Report for Dover will be posted to the website.